## **Weighted Sewer Fixture Unit Schedule**

Sti	reet	Δσ	lh!	20	٥.
UП	CCL	$\Delta$	ıuı	C-3	ъ.

Business Name: \_\_\_\_\_\_ BLD

Business Name:	Quantity of	Sewer Weighting	Total Sewer Fixture
Fixture Description	Fixtures	Value	Units (SFU)
Bar Sink		2	
Bathroom Group (hotel or motel only)		8	
Bathtub		2	
Car Wash - Self Serve (per bay)		28	
Car Wash - Auto Wash		100	
Clinic Sink		3	
Coffee Making Station - Commercial		_	
Dipper Well		3	
Dishwasher - Commercial		35	
Dishwasher - Conveyor		100	
Dishwasher - Residential type		2	
Disposal - Commercial (with independent water supply)		50	
Drinking Fountain or Watercooler		0.5	
Floor Drain or Floor Sink		2	
Hair Wash Sink		5	
Kitchen Sink - Break Room		2	
Kitchen Sink - Commercial (3 compartment sink or similar)		4	
Laundry Machine - Residential type <4.5 cu ft (12-20 lbs capacity)		8	
Laundry Machine - Commercial (maximum 35 lbs capacity)		50	
Laundry Machine - Commercial (above 35 lbs capacity is by per lb)		1.5 per lb	
Laundry Sink		4	
Lavatory		1	
Mop Sink or Service Sink		2	
RV Dump Station		25	
RV Park - (per wet space)		7	
Shower Stall - (per head)		2	
Urinal		2	
Washfountain - Circular spray		3	
Wash-Up Sink		2	
Water Closet		4	
Whirlpool Bath or Combination Bath/Shower		4	
Trench Drain - (per 30 ft of trench drain)		15	
Other			
Total Fixtures			
Amount Due (multiply total SFU by the current sewer rate)			

- (1) Recycle: Reduced by percentage as determined by director.
- (2) Multiply by 1.5 for facilities with use of greater than 12 hours and less than 16 hours operation.
- (3) Multiply by 2.0 for facilities with use of 16 hours or greater operation.
- (4) The connection fee shall not be less than the current residential connection fee for a single family dwelling per connection.

Effective Date: 10-01-2011